

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE

LISTING No. 7256-1300:100 Page 1 of 1

CATEGORY: Ionization Smoke Detector (S/MS)

LISTEE: Generation 2, 10580 Barkley #62, Overland Park KS 66212
Contact: Scott Westlake (913) 642-1518

DESIGN: Model 1001 single station smoke detector. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a single station ionization smoke detector. Primary power is furnished by 120 VAC. Secondary power must be Varta Model 6/V11R rechargeable battery. Not approved for use in new construction. Maximum wattage for light may not exceed 60 watts.



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 10, 2001**

*Listing Expires **June 30, 2002***

Authorized By: **BEN HO**, Supervising Deputy
Program Manager